

EPA ID#: 0058 System Name: City of Aurora

Sampler- Mr Andy Studer Work Phone-(605)693-3548
Title- Utilities Manager
Address- PO Box 335
Aurora SD 57002-0335

Location- City: Aurora County: Brookings
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Groundwater Supply

Population Served- 532 Service Connections- 271

Sources for Aurora

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1-FARM &FIRE	1972	66	22	Emergency	Groundwater	Vulnerable	No Treatment
02	CITY OF BROOKINGS	1991			Permanent	Purchased Groundwater	Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0058 System Name: City of Aurora

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	10/01/91	481	732	7.57	142	0	17	1.5	39.0	34.5	0.06	0.02	14.5	64	173	0	239	-0.58	10.9	1.52