

EPA ID#: 0150 System Name: City of Hartford

Sampler- Mr Craig Wagner Work Phone-(605)528-3427
Title- Utilities Manager
Address- PO Box 727 125 N Main Ave
Hartford SD 57033

Location- City: Hartford County: Minnehaha
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Groundwater Supply

Population Served- 2,634 Service Connections- 870

Sources for Hartford

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1908	156	8		Groundwater	Non-Vulnerable	Treatment At Plant
02	#2	1954	164	10		Groundwater	Non-Vulnerable	Treatment At Plant
03	#3	1978	165	10	Emergency	Groundwater	Non-Vulnerable	Treatment At Plant
04	TREATMENT PLANT				Emergency	Treatment Plant	Non-Vulnerable	Aeration Disinfection - Gas Chlorine Fluoridation - H2SiF6
05	MINNEHAHA RWS				Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0150 System Name: City of Hartford

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Raw	12/26/90	955	1166	6.97	312	0	28	6.3	169.0	47.8	0.33	1.95	5.8	388	381	0	619	-0.21	0.1	0.23

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	10/16/86	931	1220	7.44	271	0	27	5.4	156.0	51.4	0.01	0.04	7.2	409	331	0	601	+0.22	0.1	0.63