

EPA ID#: 0184 System Name: City of Kimball

Sampler- Mr Norman Munger Work Phone-(605)778-6118
Title- Utilities Manager
Address- PO Box 16
Kimball SD 57355-0016

Location- City: Kimball County: Brule
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 703 Service Connections- 360

Sources for Kimball

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	WEST	1912	1100	6		Groundwater	Non-Vulnerable	No Treatment
02	EAST	1950	1200	10	Emergency	Groundwater	Non-Vulnerable	No Treatment
03	AURORA-BRULE RWS	1982			Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0184 System Name: City of Kimball

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langelier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langelier	NO3	F
01	Raw	11/10/77	2226	0	7.30	134	0	96	20.0	407.0	90.0	2.40	0.20	116.0	1330	163	0	1387	+0.15	0.1	2.50
02	Raw	11/10/77	2060	0	6.70	118	0	89	20.0	342.0	88.0	9.40	0.20	131.0	1230	140	0	1216	0.00	0.1	2.10
Averages			2143	0	7.00	126	0	93	20.0	374.5	89.0	5.90	0.20	123.5	1280	152	0	1302		0.1	2.30

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langelier	NO3	F
01	Treated	11/28/79	2307	2350	7.60	132	0	98	21.0	406.0	89.0	0.22	0.05	119.0	1225	161	0	1380	+0.44	0.1	2.68