

EPA ID#: 0205 System Name: City of Menno

Sampler- Mr Anthony Cokens Work Phone-(605)387-5414
Title- Utilities Manager
Address- PO Box 214
Menno SD 57045-0214

Location- City: Menno County: Hutchinson
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 608 Service Connections- 352

Sources for Menno

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1957	350	8	Emergency	Groundwater	Non-Vulnerable	No Treatment
02	#2	1968	250	8	Emergency	Groundwater	Non-Vulnerable	No Treatment
03	B-Y RWS	0000	0000	0000	Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
05	POLYPHOSPHATE TR SITE				Permanent	Treatment Plant	Non-Vulnerable	Corrosion Control - Phosphates

EPA ID#: 0205 System Name: City of Menno

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	03/21/85	2106	2472	7.18	131	0	102	20.1	435.0	78.0	0.92	0.04	140.0	1206	160	0	1407	+0.05	0.1	2.43
02	Raw	03/03/81	2204	2496	7.13	130	0	116	22.7	370.0	79.4	2.31	0.20	125.0	1170	159	0	1251	-0.08	0.7	2.35
Averages			2155	2484	7.16	131	0	109	21.4	402.5	78.7	1.62	0.12	132.5	1188	160	0	1329		0.4	2.39