

EPA ID#: 0211 System Name: City of Miller

Sampler- Mr Terry Manning Work Phone-(605)853-2705
 Title- Utilities Manager
 Address- 120 West 2nd Street
 Miller SD 57362

Location- City: Miller County: Hand
 Service Area- Municipality
 PWS Owner Type- Local Government
 Water Supply Type- Purchased Surface Water Supply

Population Served- 1,489 Service Connections- 894

Sources for Miller

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1961	1245	6		Groundwater	Non-Vulnerable	Treatment At Plant
02	#2	1965	1100	6		Groundwater	Non-Vulnerable	Treatment At Plant
03	#3	1961	1245	6		Groundwater	Non-Vulnerable	No Treatment
04	#4	1976	1100	8		Groundwater	Non-Vulnerable	Treatment At Plant
05	TREAT PLT-#1 #2 #4					Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
11	MID-DAKOTA	1999			Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0211 System Name: City of Miller

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	01/24/96	2001	2365	7.49	142	0	317	20.0	199.6	60.3	0.19	0.19	30.0	1171	173	0	747	+0.21	1.2	1.82
02	Raw	09/06/89	1986	2461	7.50	138	0	311	19.2	218.0	59.0	1.60	0.17	90.2	1173	168	0	787	+0.09	0.1	1.95
03	Raw	09/06/89	1911	2568	7.70	156	0	505	15.9	89.9	28.0	0.97	0.06	101.0	1083	190	0	340	0.00	0.3	2.14
04	Raw	08/26/76	2077	0	7.30	141	0	435	19.0	141.0	44.0	0.60	0.10	88.0	1140	172	0	533	-0.30	1.0	1.80
Averages			1994	1849	7.50	144	0	392	18.5	162.1	47.8	0.84	0.13	77.3	1142	176	0	602		0.7	1.93

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
05	Treated	05/13/99	2106	2650	7.68	151	0	356	19.4	176.0	53.6	0.55	0.06	89.4	1177	184	0	660	+0.36	0.5	1.95