

EPA ID#: 0217 System Name: Town of Montrose

Sampler- Mr Daryl Sieverding Work Phone-(605)363-5065
Title- Water Superintendent
Address- PO Box 97
Montrose SD 57048-0097

Location- City: Montrose County: McCook
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Groundwater Supply

Population Served- 483 Service Connections- 205

Sources for Montrose

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1				Emergency	Treatment Plant	Non-Vulnerable	Disinfection - Gas Chlorine
02	#2	1976	0040	0016		Groundwater	Vulnerable	No Treatment
03	KINGBROOK III				Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
05	#1	1904	30	16	Emergency	Groundwater	Vulnerable	Treatment At Plant

EPA ID#: 0217 System Name: Town of Montrose

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Raw	10/03/90	1581	1848	7.17	303	0	37	7.8	216.0	114.0	0.14	2.63	23.1	726	370	0	1010	+0.11	0.5	0.16

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	05/27/93	1102	1456	7.94	267	0	37	7.5	183.0	83.1	0.02	0.03	30.0	532	326	0	799	+1.13	3.4	0.26
01	Treated	11/14/96	859	1100	7.68	280	0	24	8.1	134.0	64.3	0.04	0.09	19.0	351	342	0	599	+0.64	2.2	0.86
01	Treated	05/23/00	1192	1480	7.17	354	0	37	8.8	181.0	82.3	0.04	0.02	33.7	460	432	0	791	+0.32	5.5	0.26
Averages			1051	1345	7.60	300	0	32	8.1	166.0	76.6	0.03	0.05	27.6	448	367	0	730		3.7	0.46