

EPA ID#: 0230 System Name: Town of Oelrichs

Sampler- Mr Keith Hunt Work Phone-
Title- Water Superintendent
Address- PO Box 64
Oelrichs SD 57763

Location- City: Oelrichs County: Fall River
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Groundwater Supply

Population Served- 126 Service Connections- 76

Sources for Oelrichs

| Source | Name | Year Built | Depth (feet) | Diameter (inches) | Availability | Type | Vulnerability | Treatment |
|--------|------------------|------------|--------------|-------------------|--------------|-----------------------|----------------|--|
| 02 | TREAT SITE - #2 | | | | Emergency | Treatment Plant | Non-Vulnerable | Disinfection - Hypochlorites |
| 04 | FALL RIVER SOUTH | 2014 | | | Permanent | Purchased Groundwater | Non-Vulnerable | Water Treated By Seller - Purchased Surface Only |
| 05 | #2 | 1981 | 50 | 48 | Emergency | Groundwater | Non-Vulnerable | Treatment At Plant |

EPA ID#: 0230 System Name: Town of Oelrichs

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

| Source | Type | Date | TDS | Conductance | pH | Alk-M | Alk-P | Na | K | Ca | Mg | Fe | Mn | Cl | SO4 | HCO3 | CO3 | Hardness | Langlier | NO3 | F |
|--------|------|----------|------|-------------|------|-------|-------|-----|------|-------|------|------|------|------|------|------|-----|----------|----------|-----|------|
| 02 | Raw | 03/31/94 | 1620 | 2230 | 7.46 | 301 | 0 | 294 | 12.0 | 213.0 | 66.0 | 0.05 | 0.03 | 39.0 | 1000 | 367 | 0 | 804 | +0.77 | 7.9 | 0.15 |

| Source | Type | Date | TDS | Conductance | pH | Alk-M | Alk-P | Na | K | Ca | Mg | Fe | Mn | Cl | SO4 | HCO3 | CO3 | Hardness | Langlier | NO3 | F |
|----------|---------|----------|------|-------------|------|-------|-------|-----|------|-------|------|------|------|------|------|------|-----|----------|----------|------|------|
| 01 | Treated | 10/22/91 | 1480 | 2000 | 7.41 | 306 | 0 | 242 | 11.0 | 120.0 | 52.0 | 0.05 | 0.03 | 22.0 | 730 | 373 | 0 | 514 | +0.13 | 3.3 | 0.23 |
| 02 | Treated | 08/22/96 | 1700 | 2400 | 7.40 | 310 | 0 | 334 | 11.0 | 167.0 | 65.0 | 0.06 | 0.03 | 24.0 | 854 | 378 | 0 | 685 | +0.60 | 5.9 | 0.20 |
| 02 | Treated | 03/21/00 | 2390 | 3090 | 7.41 | 288 | 0 | 350 | 11.0 | 220.0 | 83.0 | 0.03 | 0.01 | 87.0 | 1410 | 0 | 0 | 880 | 0.00 | 18.6 | 0.50 |
| Averages | | | 1857 | 2497 | 7.41 | 301 | 0 | 309 | 11.0 | 169.0 | 66.7 | 0.05 | 0.02 | 44.3 | 998 | 250 | 0 | 693 | | 9.3 | 0.31 |