

EPA ID#: 0233 System Name: City of Onida

Sampler- Mr Tim Jost Work Phone-(605)258-2231
Title- Utilities Manager
Address- PO Box 72
Onida SD 57564

Location- City: Onida County: Sully
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 658 Service Connections- 377

Sources for Onida

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE #1					Treatment Plant	Non-Vulnerable	Disinfection - Gas Chlorine
02	#2	1958	1690	6		Groundwater	Non-Vulnerable	No Treatment
03	SUNDANCE	1959	2150	4		Groundwater	Non-Vulnerable	No Treatment
04	#4-FIRE	1977	1900	6		Groundwater	Non-Vulnerable	No Treatment
05	ENTRY POINT 01-04						Non-Vulnerable	No Treatment
06	MID DAKOTA RWS	1997			Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
10	#1-FIRE	1932	1690	6	Emergency	Groundwater	Non-Vulnerable	Treatment At Plant

EPA ID#: 0233 System Name: City of Onida

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Raw	05/02/95	1907	2640	8.05	192	0	526	18.8	56.3	24.0	2.21	0.08	271.0	852	234	0	239	+0.36	0.2	2.29
04	Raw	05/02/95	1812	2530	8.06	142	0	483	20.1	79.9	28.0	0.70	0.12	202.0	892	173	0	315	+0.40	0.2	1.80
03	Raw	05/02/95	2209	2310	7.19	147	0	53	17.7	352.8	106.2	1.79	0.10	63.0	1203	179	0	1317	+0.16	0.2	3.18
Averages			1976	2493	7.77	160	0	354	18.9	163.0	52.7	1.57	0.10	178.7	982	195	0	624		0.2	2.42