

EPA ID#: 0236 System Name: City of Parkston

Sampler- Mr Dave Doering Work Phone-(605)928-3321
Title- Utility Manager
Address- PO Box 490
Parkston SD 57366-0490

Location- City: Parkston County: Hutchinson
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 1,508 Service Connections- 750

Sources for Parkston

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#5	1968	0260	0012		Groundwater	Non-Vulnerable	No Treatment
02	#6	1973	246	14	Emergency	Groundwater	Non-Vulnerable	No Treatment
03	#3	1958	233	10		Groundwater	Non-Vulnerable	No Treatment
04	B-Y RWS				Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
06	PHOSPHATE TR POINT					Treatment Plant	Non-Vulnerable	Corrosion Control - Phosphates

EPA ID#: 0236 System Name: City of Parkston

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	05/12/77	1584	0	7.40	249	0	279	25.0	138.0	34.0	0.10	2.80	67.0	770	304	0	486	+0.10	0.1	0.60
02	Raw	01/17/89	1563	1940	7.36	211	0	273	24.1	158.0	36.8	0.24	2.19	81.0	801	257	0	546	0.00	3.8	1.27
03	Raw	11/03/78	1553	1920	7.80	208	0	279	25.4	139.0	36.3	3.20	1.50	75.3	790	254	0	496	+0.40	0.6	0.50
Averages			1567	1287	7.52	223	0	277	24.8	145.0	35.7	1.18	2.16	74.4	787	272	0	509		1.5	0.79