

**EPA ID#: 0237 System Name: Town of Peever**

Sampler- Mr Darin Roehr Work Phone-(605)448-5417  
Title- Contract Operator  
Address- PO Box 49  
Britton SD 57430

Location- City: Peever County: Roberts  
Service Area- Municipality  
PWS Owner Type- Local Government  
Water Supply Type- Purchased Groundwater Supply

Population Served- 168 Service Connections- 64

**Sources for Peever**

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1974	87	6		Groundwater	Non-Vulnerable	Treatment At Plant
02	#2	1974	85	6		Groundwater	Non-Vulnerable	Treatment At Plant
03	TREAT SITE FOR #1/#2					Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
05	BDM RWS	2004			Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

**EPA ID#: 0237 System Name: Town of Peever**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	10/18/83	1798	2550	7.30	377	0	408	11.6	117.0	44.8	2.80	0.11	60.9	885	460	0	476	+0.28	0.1	0.24
02	Raw	01/15/80	1837	2450	7.49	376	0	404	10.8	111.0	45.8	2.91	0.12	60.1	855	459	0	466	+0.23	0.1	0.31
Averages			1818	2500	7.40	377	0	406	11.2	114.0	45.3	2.86	0.12	60.5	870	460	0	471		0.1	0.28

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	05/06/92	1854	2575	7.57	384	0	400	11.1	118.0	45.5	2.12	0.08	69.8	792	468	0	482	+0.32	0.1	0.23
03	Treated	03/21/96	1796	2507	7.60	387	0	415	12.0	118.4	51.2	2.37	0.64	61.0	951	472	0	506	+0.54	0.2	0.28
03	Treated	06/29/99	1884	2530	7.69	387	0	415	11.5	109.0	48.8	1.66	0.09	62.6	908	472	0	473	+0.59	0.1	0.26
03	Treated	02/07/02	1856	2620	0.00	389	0	426	12.7	106.0	47.7	2.25	0.10	67.0	915	475	0	461	+0.49	0.1	0.25
Averages			1848	2558	5.72	387	0	414	11.8	112.9	48.3	2.10	0.23	65.1	892	472	0	481		0.1	0.26