

# EPA ID#: 0247 System Name: Town of Pollock

Sampler- Mr Travis Vetsch Work Phone-(605)889-2517  
Title- Utilities Manager  
Address- PO Box 57  
Pollock SD 57648-0057

Location- City: Pollock County: Campbell  
Service Area- Municipality  
PWS Owner Type- Local Government  
Water Supply Type- Purchased Surface Water Supply

Population Served- 241 Service Connections- 180

## Sources for Pollock

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	OLD - #1	1961	200	8	Emergency	Groundwater	Non-Vulnerable	No Treatment
02	NEW - #2	1982	220	16	Emergency	Groundwater	Non-Vulnerable	No Treatment
03	WEB RWS	0000	0000	0000	Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

**EPA ID#: 0247 System Name: Town of Pollock**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	10/06/82	1197	1976	7.30	701	0	362	13.9	78.0	26.6	1.14	0.09	104.0	245	855	0	304	+0.21	0.3	0.27
02	Raw	10/15/84	1173	1887	7.53	689	0	322	10.6	74.7	28.3	1.82	0.14	100.0	170	841	0	303	+0.38	0.1	0.26
Averages			1185	1932	7.42	695	0	342	12.3	76.4	27.5	1.48	0.12	102.0	208	848	0	304		0.2	0.27