

# EPA ID#: 0252 System Name: Town of Ramona

Sampler- Mr Paul Fischer Work Phone-  
Title- Utilities Manager  
Address- 150 N Pearce Ave PO Box 146  
Ramona SD 57054-0146

Location- City: Ramona County: Lake  
Service Area- Municipality  
PWS Owner Type- Local Government  
Water Supply Type- Groundwater Supply

Population Served- 174 Service Connections- 106

## Sources for Ramona

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	ENTRY POINT- #1&KINGBROOK II				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Gas Chlorine
02	#2	1967	820	8		Groundwater	Non-Vulnerable	Treatment At Plant
07	#1	1977	860	8	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
08	KINGBROOK II				Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

**EPA ID#: 0252 System Name: Town of Ramona**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Raw	09/07/89	1794	2622	7.85	380	0	580	14.2	44.6	13.6	1.30	0.05	95.0	862	464	0	167	+0.20	0.1	1.79

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	03/24/94	1788	2704	7.62	391	0	577	14.4	43.4	13.1	0.36	0.05	107.0	832	477	0	162	-0.35	0.7	1.78
03	Treated	10/20/99	1857	2710	7.76	389	0	563	14.6	41.3	12.1	0.14	0.02	94.0	812	475	0	153	+0.24	0.2	1.75
01	Treated	08/22/02	1844	2770	7.74	402	0	579	15.7	41.4	11.2	0.07	0.02	93.0	900	490	0	149	00.24	0.1	1.74
01	Treated	09/02/10	1841	2820	7.72	401	0	573	13.4	42.9	14.0	0.79	0.04	95.0	888	489	0	165	+0.23	0.2	1.75
01	Treated	05/10/17	810	1100	7.79	296	0	25	7.1	146.0	55.3	0.11	0.00	13.0	321	361	0	592	+0.81	0.0	0.34
Averages			1628	2421	7.73	376	0	463	13.0	63.0	21.1	0.29	0.03	80.4	751	458	0	244		0.2	1.47