

**EPA ID#: 0260 System Name: Ponderosa Mobile Home Ranch**

Sampler- Mr Robert Curran Work Phone-(605)343-6333  
Title- Water Manager  
Address- PO Box 8086  
Rapid City SD 57709-8086

Location- City: Rapid City County: Pennington  
Service Area- Trailer Court  
PWS Owner Type- Private Ownership  
Water Supply Type- Groundwater Supply

Population Served- 75 Service Connections- 30

**Sources for Ponderosa Mobile Home Ranch**

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1963	400	6	Permanent	Groundwater	Vulnerable	No Treatment

# EPA ID#: 0260 System Name: Ponderosa Mobile Home Ranch

## Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	11/16/93	166	410	7.44	203	0	3	3.0	58.0	21.0	0.05	0.03	7.0	17	248	0	232	+0.10	0.9	0.25
01	Raw	05/14/96	158	408	7.77	204	0	3	2.1	53.5	21.6	0.06	0.02	6.0	14	249	0	222	+0.36	0.8	0.28
01	Raw	01/12/99	378	422	8.01	199	1	3	2.0	50.0	21.0	0.07	0.01	1.0	16	243	1	210	+0.45	0.5	0.30
01	Raw	04/03/02	222	405	7.86	207	0	3	2.0	44.1	20.1	0.05	0.05	2.0	13	252	0	193	+0.30	0.5	0.29
01	Raw	01/31/05	247	477	7.79	219	0	4	2.2	57.4	23.4	0.05	0.01	4.5	21	267	0	240	+0.39	1.8	0.26
01	Raw	04/16/08	260	483	7.83	224	0	5	2.0	53.2	23.4	0.05	0.01	4.8	12	274	0	229	00.40	1.7	0.27
01	Raw	03/22/11	239	462	7.96	213	0	6	2.4	50.8	22.5	0.05	0.01	4.0	20	260	0	220	+0.49	1.3	0.27
01	Raw	05/19/14	234	415	7.94	203	0	4	2.4	48.7	21.0	0.00	0.00	2.0	19	247	0	208	+0.43	0.0	0.30
01	Raw	06/28/17	196	409	8.13	200	0	4	2.3	49.0	20.7	0.00	0.00	4.0	17	244	0	207	+0.62	0.0	0.29
Averages			233	432	7.86	208	0	4	2.3	51.6	21.6	0.04	0.02	3.9	16	254	0	218		0.8	0.28