

EPA ID#: 0278 System Name: Town of Ree Heights

Sampler- Mr Delton Beck Work Phone-(605)943-5531
Title- Water Manager
Address- PO Box 168
Ree Heights SD 57371-0183

Location- City: Ree Heights County: Hand
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 70 Service Connections- 30

Sources for Ree Heights

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1				Emergency	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
03	MID-DAKOTA	1999			Permanent	Purchased Surface	Vulnerable	Water Treated By Seller - Purchased Surface Only
05	#1	1956	56	18	Emergency	Groundwater	Vulnerable	Treatment At Plant
06	MID-DAKOTA/WELL ENTRY POINT				Emergency		Non-Vulnerable	No Treatment

EPA ID#: 0278 System Name: Town of Ree Heights

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	05/09/95	861	1242	7.51	451	0	158	11.4	108.5	33.8	0.15	0.34	35.0	272	550	0	410	+0.58	1.6	0.26
01	Treated	11/17/92	764	1296	7.67	445	0	141	10.6	103.0	27.5	0.11	0.29	25.6	199	543	0	370	+0.44	1.6	0.28
01	Treated	04/17/01	656	1020	7.83	310	0	114	8.2	77.1	25.4	0.02	0.20	20.0	215	378	0	297	+0.63	0.5	0.74
03	Treated	05/01/13	557	839	8.18	172	0	83	5.2	60.5	26.6	0.10	0.08	16.0	245	210	0	261	+0.63	0.2	1.15
Averages			710	1099	7.80	345	0	124	8.9	87.3	28.3	0.10	0.23	24.2	233	420	0	335		1.0	0.61