

EPA ID#: 0287 System Name: Saint Onge Sewer & Water Co

Sampler- Mr Mike Kyte Work Phone-(605)645-1276
Title- Water Manager
Address- 1221 N Main Street
Spearfish SD 57783

Location- City: St. Onge County: Lawrence
Service Area- Other residential areas
PWS Owner Type- Local Government
Water Supply Type- Groundwater Supply

Population Served- 255 Service Connections- 85

Sources for Saint Onge Sewer & Water Co

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE-#1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
03	#1	1971	600	6	Permanent	Groundwater	Vulnerable	Treatment At Plant

EPA ID#: 0287 System Name: Saint Onge Sewer & Water Co

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	11/17/93	290	560	7.29	194	0	5	3.0	91.0	23.0	0.05	0.03	1.0	112	237	0	322	+0.09	0.3	0.34
01	Raw	05/19/99	377	601	7.57	197	0	4	2.3	83.3	23.8	0.05	0.02	3.0	111	240	0	306	+0.26	0.5	0.37
01	Raw	11/29/01	305	588	7.67	202	0	5	1.9	64.4	25.9	0.05	0.05	2.5	109	247	0	15	+0.37	0.6	0.00
01	Raw	02/01/05	361	599	7.69	198	0	5	2.1	71.5	23.9	0.05	0.01	1.5	101	241	0	277	+0.34	0.5	0.36
03	Raw	05/16/17	374	592	7.52	203	0	6	2.5	76.0	22.6	0.00	0.00	0.0	103	248	0	283	+0.18	1.4	0.37
Averages			341	588	7.55	199	0	5	2.4	77.2	23.8	0.04	0.02	1.6	107	243	0	241		0.7	0.29

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	02/12/08	366	613	7.71	205	0	8	2.3	65.8	22.5	0.27	0.01	6.0	108	250	0	257	+0.34	1.1	0.36
01	Treated	10/20/10	379	610	7.51	202	0	9	2.3	81.2	22.2	0.08	0.06	5.0	106	246	0	294	+0.20	0.9	0.38
01	Treated	09/24/13	356	590	7.67	200	0	7	2.4	82.6	23.0	0.15	0.00	4.0	91	244	0	301	00.39	0.8	0.33
Averages			367	604	7.63	202	0	8	2.3	76.5	22.6	0.17	0.02	5.0	102	247	0	284		0.9	0.36