

EPA ID#: 0300 System Name: Valley View Estates

Sampler- Ms Colette Painter Work Phone-
Title- Owner
Address- 4204 East Hayes Place
Sioux Falls SD 57103

Location- City: Sioux Falls County: Minnehaha
Service Area- Trailer Court
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 205 Service Connections- 82

Sources for Valley View Estates

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
02	TREAT SITE #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
05	WELL #1	1984	30	24	Permanent	Groundwater	Vulnerable	Treatment At Plant

EPA ID#: 0300 System Name: Valley View Estates

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Raw	05/15/90	520	776	7.06	332	0	20	2.3	118.0	29.9	0.01	0.01	19.6	70	405	0	418	-0.17	2.9	0.26

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	09/10/91	627	1017	7.35	258	0	20	2.5	94.0	31.4	0.13	0.07	19.3	88	314	0	364	-0.16	2.8	0.27
02	Treated	09/25/96	648	927	7.28	383	0	20	3.3	142.0	38.3	0.06	0.02	18.0	158	467	0	512	+0.43	2.2	0.25
02	Treated	04/11/00	602	938	7.44	321	0	20	2.0	117.0	35.4	0.02	0.02	28.6	95	392	0	437	+0.44	2.5	0.25
02	Treated	07/16/02	626	1020	7.01	377	0	26	3.2	145.0	37.0	0.06	0.02	53.0	102	460	0	514	+0.17	2.6	0.27
02	Treated	05/23/06	638	1010	7.21	380	0	28	2.5	139.0	37.0	0.03	0.02	56.0	108	464	0	499	+0.35	1.4	0.27
02	Treated	06/29/09	689	1110	7.23	368	0	41	2.5	140.0	40.9	0.03	0.02	72.0	120	449	0	518	+0.35	1.8	0.32
02	Treated	05/02/12	662	1050	7.24	356	0	38	2.6	139.0	37.5	0.19	0.03	66.0	124	434	0	501	+0.35	1.8	0.33
02	Treated	07/23/14	719	1140	7.32	391	0	41	2.9	146.0	45.4	0.04	0.03	82.0	106	477	0	551	+0.48	1.3	0.33
Averages			651	1027	7.26	354	0	29	2.7	132.8	37.9	0.07	0.03	49.4	113	432	0	487		2.1	0.29