

**EPA ID#: 0310 System Name: City of Sisseton**

Sampler- Mr Gary Spencer Work Phone-(605)698-3391  
 Title- Water Superintendent  
 Address- 406 2nd Ave West  
 Sisseton SD 57262

Location- City: Sisseton County: Roberts  
 Service Area- Municipality  
 PWS Owner Type- Local Government  
 Water Supply Type- Groundwater Supply

Population Served- 2,470 Service Connections- 1,000

**Sources for Sisseton**

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1950	57	16	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
02	#2	1950	57	16		Groundwater	Non-Vulnerable	No Treatment
03	#3	1950	65	16		Groundwater	Non-Vulnerable	No Treatment
04	TREATMENT PLANT				Permanent	Treatment Plant	Non-Vulnerable	Aeration Coagulation, Softening - KMnO4 Disinfection - Gas Chlorine Filtration - Pressure Sand Corrosion Control - Fluoridation - H2SiF6
05	#5	1987	60	16	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
08	PRETREATMENT-#1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Gas Chlorine
09	PRETREATMENT-#5				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Gas Chlorine

**EPA ID#: 0310 System Name: City of Sisseton**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	03/21/89	651	903	7.34	296	0	28	5.8	114.0	43.9	1.55	0.30	5.0	218	361	0	465	0.03	0.1	0.24
02	Raw	02/01/77	749	0	7.50	303	0	32	6.0	120.0	48.0	7.80	0.49	8.0	258	370	0	496	+0.24	0.1	0.20
03	Raw	07/18/90	666	9060	7.29	288	0	24	5.3	116.0	39.1	1.51	0.28	6.4	188	351	0	451	-0.02	0.1	0.24
04	Raw	08/24/94	417	636	7.37	242	0	19	4.2	80.7	31.1	1.44	0.03	9.5	123	295	0	329	+0.02	0.1	0.23
Averages			621	2650	7.38	282	0	26	5.3	107.7	40.5	3.08	0.28	7.2	197	344	0	435		0.1	0.23

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
04	Treated	08/24/94	0	0	0.00	0	0	0	0.0	0.0	0.0	0.06	0.08	0.0	0	0	0	0	0.00	0.0	0.00
04	Treated	05/29/97	457	706	7.56	243	0	19	4.2	81.7	32.2	0.08	0.02	9.0	145	296	0	337	+0.31	0.1	1.39
04	Treated	09/16/99	488	713	7.68	253	0	20	4.1	84.6	31.5	0.15	0.05	5.8	125	309	0	341	+0.46	0.1	1.36
04	Treated	06/05/03	512	737	7.33	268	0	19	4.4	104.0	33.9	0.05	0.08	9.0	145	327	0	399	+0.22	0.1	1.31
04	Treated	04/27/06	522	785	7.49	275	0	20	4.7	95.4	35.5	0.03	0.02	9.0	148	336	0	384	+0.35	0.1	1.33
04	Treated	04/23/09	779	1090	7.64	298	0	31	6.7	142.0	54.5	0.03	0.02	14.0	314	364	0	579	+0.66	0.2	0.28
04	Treated	03/25/15	520	778	7.77	241	0	21	4.5	92.0	35.4	0.00	0.00	12.0	164	294	0	375	+0.56	0.0	1.16
Averages			468	687	6.50	225	0	19	4.1	85.7	31.9	0.06	0.04	8.4	149	275	0	345		0.1	0.98