

EPA ID#: 0327 System Name: Town of Tabor

Sampler- Mr Gerald Hofmann Work Phone-(605)463-2501
Title- Utilities Manager
Address- PO Box 146
Tabor SD 57063-0146

Location- City: Tabor County: Bon Homme
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 423 Service Connections- 219

Sources for Tabor

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1954	115	8	Emergency	Groundwater	Non-Vulnerable	No Treatment
02	#2	1969	115	8	Emergency	Groundwater	Non-Vulnerable	No Treatment
03	B-Y RWS	1982	0000	0000	Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0327 System Name: Town of Tabor

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	08/10/78	1645	0	7.80	264	0	330	21.3	126.0	37.3	0.10	0.02	192.0	610	322	0	468	0.00	0.1	1.10
02	Raw	08/10/78	1619	0	7.50	259	0	340	20.9	118.0	35.1	0.04	0.02	193.0	650	316	0	439	0.00	0.1	1.10
Averages			1632	0	7.65	262	0	335	21.1	122.0	36.2	0.07	0.02	192.5	630	319	0	454		0.1	1.10

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
03	Treated	05/14/13	429	654	9.32	70	13	77	6.0	33.9	14.8	0.03	0.02	14.0	227	54	16	146	+1.16	0.2	1.19