

EPA ID#: 0335 System Name: Town of Tulare

Sampler- Mr Ron Neeman Work Phone-(605)450-8204
Title- Utilities Manager
Address- PO Box 216
Tulare SD 57476-0216

Location- City: Tulare County: Spink
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 217 Service Connections- 115

Sources for Tulare

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1					Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
04	MID-DAKOTA RWS	2002			Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
05	#1	1963	1253	4	Emergency	Groundwater	Non-Vulnerable	Treatment At Plant

EPA ID#: 0335 System Name: Town of Tulare

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	11/09/94	2009	2834	7.18	116	0	530	17.2	100.7	29.9	0.43	0.11	131.3	1165	142	0	374	-0.48	0.7	1.78
01	Treated	10/09/96	2030	2754	7.91	142	0	502	18.9	106.0	32.7	0.84	0.05	134.0	1120	173	0	399	+0.35	0.2	1.85
01	Treated	11/04/99	2084	2860	7.63	118	0	489	19.1	100.0	29.6	0.52	0.05	141.5	1145	144	0	372	-0.04	0.3	1.79
Averages			2041	2816	7.57	125	0	507	18.4	102.2	30.7	0.60	0.07	135.6	1143	153	0	382		0.4	1.81