

EPA ID#: 0336 System Name: Town of Twin Brooks

Sampler- Mr John Gustafson Work Phone-
Title- Water Superintendent
Address- PO Box 20
Twin Brooks SD 57269-0020

Location- City: Twin Brooks County: Grant
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Groundwater Supply

Population Served- 69 Service Connections- 32

Sources for Twin Brooks

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
02	TREAT SITE - #2				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
04	#2	1969	70	6	Permanent	Groundwater	Vulnerable	Treatment At Plant

EPA ID#: 0336 System Name: Town of Twin Brooks

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Treated	03/01/94	1098	1430	7.38	310	0	72	10.6	191.0	58.1	3.54	0.11	12.0	520	378	0	716	+0.65	0.1	0.29
02	Treated	12/01/98	1157	1500	7.39	316	0	73	11.9	187.0	57.1	2.78	0.11	14.0	550	386	0	702	+0.51	0.1	0.32
02	Treated	02/28/02	1145	1540	7.17	317	0	68	12.1	185.0	54.6	3.12	0.10	14.0	546	387	0	687	+0.29	0.1	0.30
02	Treated	03/16/05	1115	1480	7.19	312	0	70	11.1	182.0	55.8	2.82	0.09	19.0	518	381	0	684	+0.30	0.1	0.29
02	Treated	02/28/08	1142	1460	7.32	316	0	67	12.8	204.0	54.2	3.04	0.10	16.0	545	386	0	732	+0.48	0.2	0.32
02	Treated	11/04/10	1123	1460	7.34	319	0	64	10.9	188.0	60.2	3.32	0.11	8.0	561	389	0	717	+0.47	0.2	0.35
Averages			1130	1478	7.30	315	0	69	11.6	189.5	56.7	3.10	0.10	13.8	540	385	0	706		0.1	0.31