

EPA ID#: 0341 System Name: Town of Veblen

Sampler- Mr John Herman Work Phone-(605)738-2521
 Title- Utilities Manager
 Address- PO Box 96
 Veblen SD 57270-0096

Location- City: Veblen County: Marshall
 Service Area- Municipality
 PWS Owner Type- Local Government
 Water Supply Type- Purchased Groundwater Supply

Population Served- 526 Service Connections- 120

Sources for Veblen

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1972	150	8		Groundwater	Non-Vulnerable	Treatment At Plant
02	#2	1978	155	8		Groundwater	Non-Vulnerable	Treatment At Plant
03	#3	1993	165			Groundwater	Non-Vulnerable	No Treatment
04	ENTRY POINT #1 & #2					Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
06	BDM RWS	2000			Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0341 System Name: Town of Veblen

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
04	Raw	03/20/95	1639	2071	7.24	306	0	185	15.8	237.3	65.0	1.54	1.17	45.4	858	373	0	860	+0.40	0.3	0.30

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	01/26/93	0	0	0.00	0	0	0	0.0	0.0	0.0	1.17	1.19	0.0	0	0	0	0	0.00	0.0	0.00
04	Treated	09/16/97	1701	2100	7.17	292	0	184	15.4	232.0	65.5	1.04	1.20	39.0	903	356	0	849	+0.29	0.1	0.27
Averages			851	1050	3.59	146	0	92	7.7	116.0	32.8	1.11	1.20	19.5	452	178	0	425		0.1	0.14