

# EPA ID#: 0354 System Name: Pelican Plaza

Sampler- Mr Doug Anderson Work Phone-  
Title- Water Manager  
Address- PO Box 694  
Watertown SD 57201-0694

Location- City: Watertown County: Codington  
Service Area- Trailer Court  
PWS Owner Type- Private Ownership  
Water Supply Type- Groundwater Supply

Population Served- 100 Service Connections- 68

## Sources for Pelican Plaza

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1978	34	6	Permanent	Groundwater	Vulnerable	No Treatment
02	#2	1978	34	6	Permanent	Groundwater	Vulnerable	No Treatment
03	#3	1987	40	5	Permanent	Groundwater	Vulnerable	No Treatment
04	#4	1987	40	5	Permanent	Groundwater	Vulnerable	No Treatment
05	S ENTRY PT-#3#4				Permanent		Non-Vulnerable	No Treatment
07	N ENTRY PT-#1#2				Permanent		Non-Vulnerable	No Treatment

**EPA ID#: 0354 System Name: Pelican Plaza**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	01/26/94	472	770	8.16	358	0	15	2.9	90.4	44.7	0.82	0.25	8.0	54	437	0	410	+1.19	5.8	0.26
03	Raw	02/25/88	453	740	7.47	310	0	20	2.7	71.5	43.8	0.03	0.04	14.4	64	378	0	359	0.00	8.0	0.42
03	Raw	05/07/90	471	742	7.36	293	0	10	1.8	90.9	46.7	0.01	0.03	33.0	53	357	0	419	-0.03	9.0	0.29
03	Raw	01/25/96	418	715	7.53	322	0	13	2.0	84.0	42.0	0.06	0.02	17.0	39	393	0	383	+0.43	4.4	0.37
05	Raw	02/04/99	458	696	7.78	322	0	14	2.7	80.2	36.9	0.02	0.02	13.1	42	393	0	352	+0.65	5.3	0.35
05	Raw	06/26/02	468	774	7.47	324	0	12	2.7	88.0	41.3	0.04	0.02	16.0	38	395	0	390	+0.38	5.2	0.31
05	Raw	03/29/05	462	746	7.81	308	0	14	2.6	81.7	36.9	0.03	0.02	24.0	44	376	0	356	+0.67	6.4	0.26
05	Raw	02/07/08	431	749	7.60	318	0	14	2.8	90.6	35.8	0.04	0.03	21.0	27	388	0	374	+0.52	6.5	0.32
05	Raw	03/29/11	486	801	7.42	352	0	21	2.1	87.0	51.3	0.02	0.02	26.0	32	429	0	428	+0.36	9.9	0.47
05	Raw	04/23/14	463	771	7.49	341	0	16	1.6	91.5	48.3	0.06	0.07	27.0	32	416	0	427	+0.44	6.6	0.45
07	Raw	03/29/17	486	821	7.84	320	0	19	2.4	92.0	39.0	0.00	0.00	36.0	49	390	0	390	+0.76	7.1	0.43
Averages			461	757	7.63	324	0	15	2.4	86.2	42.4	0.10	0.05	21.4	43	396	0	390		6.7	0.36