

EPA ID#: 0371 System Name: City of Wilmot

Sampler- Mr Tim Reyelts Work Phone-(605)938-4811
 Title- Utilities Manager
 Address- PO Box 40 - 516 Main Street
 Wilmot SD 57279-0040

Location- City: Wilmot County: Roberts
 Service Area- Municipality
 PWS Owner Type- Local Government
 Water Supply Type- Purchased Groundwater Supply

Population Served- 492 Service Connections- 279

Sources for Wilmot

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	GRANT-ROBERTS RW	2003			Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
02	#2-FIRE	1969	80	4	Emergency	Groundwater	Non-Vulnerable	Treatment At Plant
03	TR PLANT FOR #1/#2					Treatment Plant	Non-Vulnerable	Aeration Coagulation, Softening - Disinfection - Gas Chlorine Filtration - Pressure Sand Corrosion Control - Caustic Soda Phosphates Fluoridation - H2SiF6
04	NEW #1-FIRE	1994	80	4	Emergency	Groundwater	Non-Vulnerable	Treatment At Plant

EPA ID#: 0371 System Name: City of Wilmot

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	11/16/93	1733	2180	7.98	352	0	237	9.2	207.0	90.0	6.20	0.28	53.4	1002	429	0	887	+1.34	0.2	0.22
02	Raw	11/21/85	1761	2310	7.30	414	0	267	11.5	183.0	76.6	0.15	0.40	68.7	852	505	0	772	+0.39	0.1	0.22
Averages			1747	2245	7.64	383	0	252	10.4	195.0	83.3	3.18	0.34	61.1	927	467	0	830		0.2	0.22

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
03	Treated	11/30/95	1795	2344	0.00	396	0	269	10.3	194.8	75.9	3.20	0.17	70.0	855	483	0	799	+0.67	0.1	0.23
03	Treated	11/03/98	1805	2250	7.52	385	0	266	10.4	183.0	78.0	0.79	0.11	72.0	868	470	0	778	+0.65	0.1	1.28
03	Treated	02/07/02	1766	2340	0.00	384	0	245	10.7	177.0	77.7	0.44	0.13	66.0	840	468	0	762	+0.82	0.1	1.35
Averages			1789	2311	2.51	388	0	260	10.5	184.9	77.2	1.48	0.14	69.3	854	474	0	780		0.1	0.95