

EPA ID#: 0375 System Name: Town of Wolsey

Sampler- Mr Shaylin Quam Work Phone-(605)883-4710
Title- Water Manager
Address- PO Box 356
Wolsey SD 57384-0356

Location- City: Wolsey County: Beadle
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 376 Service Connections- 300

Sources for Wolsey

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1973	1140	2	Emergency	Groundwater	Non-Vulnerable	No Treatment
05	MID DAKOTA RURAL WATER	0000	0000	0000	Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0375 System Name: Town of Wolsey

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	05/25/83	2144	2600	7.10	132	0	196	20.5	360.0	73.5	1.86	0.13	137.0	1270	161	0	1201	-0.05	0.1	2.56
01	Raw	02/18/81	2280	2704	7.29	137	0	202	21.5	331.0	75.2	0.10	0.08	127.0	1192	167	0	1136	+0.06	0.6	2.47
04	Raw	04/26/84	515	817	6.87	335	0	31	7.7	109.0	30.7	2.72	0.83	14.3	127	409	0	398	+0.06	0.1	0.18
Averages			1646	2040	7.09	201	0	143	16.6	266.7	59.8	1.56	0.35	92.8	863	246	0	912		0.3	1.74