

EPA ID#: 0546 System Name: Sacora Mobile Home Park

Sampler- Mr Jamie Miller Work Phone-
Title- Water Operator
Address- 14240 Sturgis Road
Piedmont SD 57769

Location- City: Piedmont County: Meade
Service Area- Trailer Court
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 42 Service Connections- 18

Sources for Sacora Mobile Home Park

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
03	#1	1990	160	6	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant

EPA ID#: 0546 System Name: Sacora Mobile Home Park

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	10/11/91	261	500	7.50	262	0	2	2.0	67.0	30.0	0.05	0.03	2.0	7	320	0	291	-0.05	0.2	0.24
01	Raw	04/24/97	318	690	7.58	330	0	3	2.0	110.0	16.0	0.05	0.03	9.0	16	403	0	341	+0.70	1.6	0.10
01	Raw	09/20/00	564	871	7.23	317	0	11	1.5	124.0	29.0	0.02	0.02	23.0	106	387	0	429	+0.26	2.9	0.23
01	Raw	03/12/03	409	686	8.06	296	0	7	1.4	82.6	30.5	0.05	0.05	13.3	54	361	0	332	+0.94	1.4	0.25
Averages			388	687	7.59	301	0	6	1.7	95.9	26.4	0.04	0.03	11.8	46	368	0	348		1.5	0.20

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	05/17/06	457	759	7.09	332	0	6	1.4	120.0	26.3	0.03	0.02	32.0	53	405	0	408	+0.15	1.7	0.20
01	Treated	04/21/09	372	679	7.68	334	0	7	0.9	91.6	16.8	0.05	0.01	6.3	10	408	0	298	+0.66	3.6	0.16
01	Treated	05/29/12	500	849	7.46	303	0	12	1.7	127.0	30.2	0.05	0.01	18.2	146	369	0	441	+0.54	2.4	0.24
Averages			443	762	7.41	323	0	8	1.3	112.9	24.4	0.04	0.01	18.8	70	394	0	382		2.6	0.20