

EPA ID#: 0619 System Name: Oahe Plains Systems Corporation

Sampler- Mr Doug Ripley Work Phone-(605)224-7994
 Title- Manager
 Address- 225 Spring Creek Drive
 Pierre SD 57501

Location- City: Pierre County: Hughes
 Service Area- Other residential areas
 PWS Owner Type- Private Ownership
 Water Supply Type- Purchased Surface Water Supply

Population Served- 257 Service Connections- 103

Sources for Oahe Plains Systems Corporation

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	MISSOURI RIVER	1978	0000	0000		Surface Water	Vulnerable	Treatment At Plant
02	MID-DAKOTA RWS	1997			Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
04	TREATMENT PLANT					Treatment Plant	Non-Vulnerable	Aeration Coagulation, Softening - Alum Disinfection - Gas Chlorine Filtration - Mixed Media Mixing Device

EPA ID#: 0619 System Name: Oahe Plains Systems Corporation

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO4	CO3	Hardness	Langlier	NO3	F
01	Treated	12/18/95	462	648	7.90	153	0	73	5.2	54.5	22.6	0.06	0.02	11.0	235	187	0	229	+0.28	0.2	0.42