

EPA ID#: 0876 System Name: Westview Homeowners Association

Sampler- Mr Pat Hasson Work Phone-
Title- System Manager
Address- 3518 Westview Drive
Spearfish SD 57783

Location- City: Spearfish County: Lawrence
Service Area- Homeowners Association
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 103 Service Connections- 34

Sources for Westview Homeowners Association

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
04	#1	1978	273	5	Permanent	Groundwater	Vulnerable	Treatment At Plant

EPA ID#: 0876 System Name: Westview Homeowners Association

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	04/16/91	371	660	7.29	338	0	4	2.0	79.0	28.0	0.05	0.03	4.0	1	412	0	313	-0.09	0.9	0.24

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	06/12/96	423	689	7.37	351	0	6	1.7	99.6	30.5	0.06	0.02	12.0	20	428	0	374	+0.38	1.1	0.28
01	Treated	05/19/99	400	739	8.01	352	0	5	2.0	86.0	27.0	0.02	0.01	13.0	21	429	1	326	+0.93	1.1	0.50
01	Treated	06/28/02	336	633	7.63	307	0	14	1.5	78.7	25.7	0.05	0.05	18.3	15	375	0	302	+0.51	0.0	0.23
01	Treated	02/02/05	334	716	7.35	306	0	8	1.6	87.0	28.7	0.05	0.01	31.3	17	373	0	335	+0.27	2.4	0.20
01	Treated	05/11/11	415	761	7.68	350	0	8	1.9	109.0	31.3	0.03	0.02	31.0	21	427	0	401	+0.73	1.5	0.29
01	Treated	03/25/14	391	745	7.97	337	0	10	1.9	101.0	30.9	0.00	0.00	30.7	20	411	0	378	+1.00	1.8	0.22
01	Treated	05/16/17	425	765	7.53	331	0	11	2.0	103.0	31.7	0.00	0.00	33.0	22	404	0	388	+0.53	1.7	0.25
Averages			389	721	7.65	333	0	9	1.8	94.9	29.4	0.03	0.02	24.2	19	407	0	358		1.4	0.28