

EPA ID#: 0938 System Name: Littleburg Elementary School

Sampler- Mr Tim Cournoyer Work Phone-(605)856-3509
Title- Dir. Of Maintenance
Address- PO Box 87
Mission SD 57555

Location- City: Mission County: Todd
Service Area- School
PWS Owner Type- Local Government
Water Supply Type- Groundwater Supply

Population Served- 48 Service Connections- 4

Months that System is Open to Public-Season Opening Date- September 1st Season Closing Date- May 30th

Sources for Littleburg Elementary School

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE-#1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
03	#1	1959	150	4	Permanent	Groundwater	Vulnerable	Treatment At Plant

EPA ID#: 0938 System Name: Littleburg Elementary School

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langelier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langelier	NO3	F
01	Raw	10/17/95	248	364	7.70	158	0	15	11.6	44.7	8.3	0.05	0.02	3.0	10	193	0	146	+0.06	3.4	0.61
01	Raw	09/23/98	270	366	7.66	158	0	14	11.6	42.6	7.2	0.08	0.02	3.0	10	193	0	136	-0.01	4.0	0.60
01	Raw	04/17/02	272	375	7.64	160	0	16	11.6	42.2	7.1	0.03	0.03	3.0	10	195	0	135	-0.02	3.1	0.58
01	Raw	09/29/10	259	366	7.61	161	0	14	11.4	41.4	7.6	0.03	0.07	3.0	10	196	0	135	-0.05	3.2	0.62
Averages			262	368	7.65	159	0	15	11.6	42.7	7.6	0.05	0.04	3.0	10	194	0	138		3.4	0.60

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langelier	NO3	F
01	Treated	10/09/13	265	358	7.77	161	0	15	11.6	43.1	7.4	0.00	0.03	4.0	10	196	0	138	+0.12	2.6	0.59