

EPA ID#: 2001 System Name: Sunnyside Mobile Home Park II

Sampler- Mr Darold Buskohl Work Phone-
Title- Water Operator
Address- 4800 Everest-#87
Rapid City SD 57702-9678

Location- City: Rapid City County: Pennington
Service Area- Trailer Court
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 250 Service Connections- 94

Sources for Sunnyside Mobile Home Park II

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
04	#1	1973	720	5	Permanent	Groundwater	Vulnerable	Treatment At Plant

EPA ID#: 2001 System Name: Sunnyside Mobile Home Park II

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	04/02/91	202	430	7.46	206	0	4	3.0	55.0	21.0	0.05	0.03	4.0	1	251	0	224	-0.29	0.3	0.26

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	03/26/97	225	306	7.58	205	0	2	2.1	51.5	22.3	0.06	0.02	2.3	17	250	0	220	+0.13	0.5	0.29
01	Treated	01/25/00	222	425	7.58	212	0	2	2.0	50.0	19.0	0.03	0.01	1.0	18	259	0	203	+0.07	0.3	0.40
04	Treated	03/11/03	223	412	8.04	206	0	4	2.7	45.1	21.3	0.05	0.05	2.0	10	252	0	200	+0.50	0.7	0.29
01	Treated	09/14/05	211	418	8.00	207	0	4	1.9	45.4	20.4	0.00	0.00	3.8	0	252	0	197	+0.47	0.5	0.27
01	Treated	01/13/09	202	419	7.92	206	0	4	1.4	36.8	20.0	0.09	0.01	0.8	15	252	0	174	+0.30	0.7	0.28
01	Treated	01/05/12	234	425	7.94	205	0	4	2.4	44.7	20.2	0.05	0.01	3.2	18	250	0	195	+0.40	0.5	0.31
01	Treated	10/21/14	249	422	8.06	205	0	5	2.6	49.6	20.8	0.00	0.00	3.6	20	251	0	209	+0.56	0.9	0.27
Averages			224	404	7.87	207	0	4	2.2	46.2	20.6	0.04	0.01	2.4	14	252	0	200		0.6	0.30