

## EPA ID#: 2018 System Name: Jamesville Colony

Sampler- Mr Benny Wurtz Work Phone-(605)364-7307  
Title- Water Sampler  
Address- 43582 NE James River Road  
Utica SD 57067

Location- City: Utica County: Yankton  
Service Area- Homeowners Association  
PWS Owner Type- Private Ownership  
Water Supply Type- Groundwater Supply

Population Served- 120 Service Connections- 26

### Sources for Jamesville Colony

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	0000	548	5	Permanent	Groundwater	Non-Vulnerable	No Treatment
02	B-Y RWS	0000	0000	0000	Emergency	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

**EPA ID#: 2018 System Name: Jamesville Colony**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO4	CO3	Hardness	Langlier	NO3	F
01	Raw	09/09/91	1962	2244	7.58	135	0	109	20.8	316.0	63.0	0.83	0.18	114.0	994	165	0	1048	+0.29	0.9	2.67
01	Raw	03/04/96	1828	2126	7.42	136	0	107	21.1	332.7	67.2	1.78	0.15	112.0	969	166	0	1107	+0.36	0.1	2.76
01	Raw	07/29/99	1857	2150	7.27	138	0	108	21.4	330.0	67.2	1.59	0.14	117.1	998	168	0	1100	+0.21	0.1	2.77
01	Raw	04/03/02	1877	2300	7.34	135	0	109	21.1	291.0	59.8	1.93	0.13	108.0	1010	165	0	973	+0.21	0.1	2.76
01	Raw	06/21/11	1900	2260	7.44	136	0	108	20.0	336.0	72.8	1.82	0.13	112.0	1070	166	0	1140	+0.37	0.2	2.88
Averages			1885	2216	7.41	136	0	108	20.9	321.1	66.0	1.59	0.15	112.6	1008	166	0	1074		0.3	2.77