

# EPA ID#: 2051 System Name: Long Lake Colony

Sampler- Mr John Waldner Work Phone-(605)439-3410  
Title- Business Manager  
Address- 36848 123rd Street  
Westport SD 57481-8104

Location- City: Westport County: Brown  
Service Area- Homeowners Association  
PWS Owner Type- Private Ownership  
Water Supply Type- Groundwater Supply

Population Served- 95 Service Connections- 23

## Sources for Long Lake Colony

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1				Permanent	Treatment Plant	Non-Vulnerable	Filtration -
03	#1	1987	1158	5	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant

# EPA ID#: 2051 System Name: Long Lake Colony

## Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	11/01/95	2037	3297	7.94	606	0	746	16.5	18.2	8.2	0.26	0.05	608.0	342	739	0	76	79.20	0.1	2.60
01	Raw	02/26/99	1893	3500	7.97	611	0	764	15.9	18.0	8.1	0.45	0.03	609.0	298	745	0	78	+0.29	0.1	2.61
01	Raw	10/23/01	2156	3710	7.81	605	0	794	16.8	18.0	7.7	0.97	0.04	660.0	308	738	0	77	+0.10	0.1	2.61
01	Raw	03/23/05	2167	3560	7.93	618	0	785	17.3	16.6	7.9	0.15	0.02	645.0	326	754	0	74	+0.20	0.1	2.52
01	Raw	11/09/07	2174	3530	8.05	627	0	804	17.8	20.3	8.1	0.10	0.02	670.0	306	765	0	84	+0.41	0.2	2.62
03	Raw	06/23/11	2217	3610	7.88	603	0	756	15.4	18.7	9.6	0.26	0.06	610.0	321	736	0	86	+0.18	0.2	2.71
Averages			2107	3535	7.93	612	0	775	16.6	18.3	8.3	0.37	0.04	633.7	317	746	0	79		0.1	2.61

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	04/15/14	2189	3690	7.92	635	0	740	15.1	18.3	9.5	0.14	0.08	640.0	223	775	0	85	+0.24	0.0	2.56