

## EPA ID#: 2077 System Name: Upland Colony

Sampler- Mr Duane Wurtz Work Phone-  
Title- Upland Colony  
Address- 24221 412th Avenue  
Artesian SD 57314

Location- City: Artesian County: Sanborn  
Service Area- Homeowners Association  
PWS Owner Type- Private Ownership  
Water Supply Type- Groundwater Supply

Population Served- 150 Service Connections- 18

### Sources for Upland Colony

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE-#1				Permanent	Treatment Plant	Non-Vulnerable	Filtration - Zeolite
04	#2				Emergency	Groundwater	Non-Vulnerable	No Treatment
05	#1	1976	170	6	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant

**EPA ID#: 2077 System Name: Upland Colony**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	07/19/94	2017	2940	7.64	170	0	724	9.4	2.7	1.2	0.10	0.02	128.4	1250	207	0	12	-1.20	0.1	1.08
01	Raw	05/13/97	2036	2740	7.38	148	0	324	25.0	203.0	61.0	1.67	0.05	123.0	1144	181	0	758	+0.12	0.1	0.84
01	Raw	05/17/00	2044	2590	7.44	150	0	320	23.0	202.0	55.1	1.69	0.06	130.0	1100	183	0	731	+0.19	0.1	0.89
01	Raw	02/18/04	2042	2660	7.48	150	0	342	23.4	196.0	58.3	1.58	0.05	125.0	1180	183	0	729	+0.21	0.1	0.88
01	Raw	04/03/07	2045	2760	7.41	155	0	334	24.6	202.0	57.0	1.80	0.05	119.0	1190	189	0	739	+0.17	0.1	0.89
Averages			2037	2738	7.47	155	0	409	21.1	161.1	46.5	1.37	0.05	125.1	1173	189	0	594		0.1	0.92