

EPA ID#: 2094 System Name: Whispering Willows

Sampler- Mr Bob Powles Work Phone-
Title- Water Manager
Address- 7963 Deerview Road
Piedmont SD 57769

Location- City: Box Elder County: Pennington
Service Area- Trailer Court
PWS Owner Type- Private Ownership
Water Supply Type- Purchased Groundwater Supply

Population Served- 90 Service Connections- 35

Sources for Whispering Willows

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1					Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
04	#1-IRRIGATION	1985	30	6	Emergency	Groundwater	Vulnerable	Treatment At Plant
05	BOX ELDER	2006			Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 2094 System Name: Whispering Willows

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langelier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langelier	NO3	F
01	Raw	03/23/95	1880	2400	7.38	322	0	182	8.0	313.0	24.0	0.05	0.03	68.0	810	393	0	881	+0.88	3.6	0.30
01	Raw	09/30/97	1368	1870	7.32	381	0	123	5.7	194.0	80.4	0.05	0.02	32.0	665	465	0	815	+0.51	5.0	0.37
01	Raw	10/04/00	1330	1720	7.27	372	0	19	5.0	80.0	22.0	0.16	0.03	33.0	596	454	1	290	+0.13	4.1	0.30
Averages			1526	1997	7.32	358	0	108	6.2	195.7	42.1	0.09	0.03	44.3	690	437	0	662		4.2	0.32

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langelier	NO3	F
01	Treated	03/29/04	1100	1598	7.61	351	0	116	5.2	149.0	67.6	0.05	0.01	29.8	434	428	0	650	+0.82	4.6	0.37