

## EPA ID#: 2154 System Name: Oahe Acres

Sampler- Mr Al Thomas Work Phone-(605)945-0437  
Title- Water Manager  
Address- 29111 Holly Road  
Pierre SD 57501

Location- City: Pierre County: Hughes  
Service Area- Homeowners Association  
PWS Owner Type- Private Ownership  
Water Supply Type- Purchased Surface Water Supply

Population Served- 93 Service Connections- 40

### Sources for Oahe Acres

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1					Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
03	MID-DAKOTA RWS				Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
04	#1	1963	64	6		Groundwater	Vulnerable	Treatment At Plant

**EPA ID#: 2154 System Name: Oahe Acres**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	03/03/95	2032	2475	6.94	461	0	157	18.8	357.3	79.6	1.99	3.48	18.0	1105	562	0	1220	+0.42	0.1	0.27
01	Treated	06/10/98	1695	2040	6.99	381	0	133	12.1	266.0	64.0	0.19	2.76	22.0	815	465	0	928	+0.29	0.1	0.36
Averages			1864	2258	6.97	421	0	145	15.5	311.7	71.8	1.09	3.12	20.0	960	514	0	1074		0.1	0.32