

EPA ID#: 2206 System Name: City of Pringle

Sampler- Mr Robert Morgan Work Phone-(605)673-2681
Title- Treasurer
Address- PO Box 139
Pringle SD 57773

Location- City: Pringle County: Custer
Service Area- Restaurant
PWS Owner Type- Local Government
Water Supply Type- Groundwater Supply

Population Served- 60 Service Connections- 13

Months that System is Open to Public-Season Opening Date- January 1st Season Closing Date- December 31st

Sources for Pringle

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1950	90	6	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
02	#2	1996	325	6	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
03	TREAT SITE - WELLS #1/#2				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
05	NEW COMMUNITY WELL	2001	60	5	Emergency	Groundwater	Non-Vulnerable	No Treatment

EPA ID#: 2206 System Name: City of Pringle

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
03	Raw	03/29/12	466	818	7.42	278	0	36	5.7	91.5	27.5	0.03	0.02	59.0	48	339	0	342	+0.28	3.7	0.33