

EPA ID#: 2242 System Name: Sanborn Central School District

Sampler- Mr Mark Van Overshelde Work Phone-(605)495-4183
Title- Sanborn School
Address- 40405 SD Highway 34
Forestburg SD 57314

Location- City: Forestburg County: Sanborn
Service Area- School
PWS Owner Type- State Government
Water Supply Type- Groundwater Supply

Population Served- 219 Service Connections- 2

Months that System is Open to Public-Season Opening Date- September 1st Season Closing Date- May 31st

Sources for Sanborn Central School District

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	2004	200	8	Permanent	Groundwater	Non-Vulnerable	No Treatment

EPA ID#: 2242 System Name: Sanborn Central School District

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	09/08/04	1737	2590	7.76	574	0	605	11.5	22.5	7.5	0.12	0.02	145.0	627	700	0	87	+0.16	0.1	0.89
01	Raw	05/09/07	1714	2680	7.83	578	0	590	12.6	22.1	7.4	0.29	0.02	144.0	591	705	0	86	+0.22	0.1	0.86
Averages			1726	2635	7.80	576	0	598	12.1	22.3	7.5	0.21	0.02	144.5	609	703	0	87		0.1	0.88