

EPA ID#: 2249 System Name: Rolling Dice Subdivision

Sampler- Mr Al Sage Work Phone-(605)391-7483
Title- Contract Operator
Address- 5310 Ebony Place
Piedmont SD 57769

Location- City: Rapid City County: Meade
Service Area- Homeowners Association
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 120 Service Connections- 48

Sources for Rolling Dice Subdivision

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	2002	1920	6	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
02	TREAT SITE- #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites Corrosion Control - Phosphates

EPA ID#: 2249 System Name: Rolling Dice Subdivision

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Treated	06/08/05	461	742	7.54	197	0	25	6.0	88.4	25.4	0.56	0.01	5.5	191	240	0	325	+0.28	0.5	0.38
02	Treated	04/14/08	479	725	7.61	195	0	24	6.0	83.1	22.3	0.78	0.01	4.8	180	238	0	299	+0.32	0.5	0.41
02	Treated	04/06/11	455	705	7.50	194	0	24	6.2	77.5	24.5	1.39	0.03	2.3	185	237	0	294	+0.18	0.1	0.39
02	Treated	05/06/14	448	667	7.42	194	0	23	6.0	95.0	26.0	0.48	0.01	3.0	179	236	0	340	+0.20	0.1	0.40
02	Treated	03/13/17	432	700	7.63	199	0	21	5.9	88.1	24.2	0.48	0.02	3.3	180	242	0	320	+0.37	0.0	0.41
Averages			455	708	7.54	196	0	24	6.0	86.4	24.5	0.74	0.02	3.8	183	239	0	316		0.2	0.40