

EPA ID#: 2277 System Name: Clark Rural Water-Kampeska

Sampler- Mr Terry Kaufman Work Phone-
Title- Manager
Address- PO Box 162
Clark SD 57225

Location- City: Clark County: Codington, Clark, Day, Hamlin
Service Area- Other residential areas
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 578 Service Connections- 231

Sources for Clark Rural Water-Kampeska

| Source | Name | Year Built | Depth (feet) | Diameter (inches) | Availability | Type | Vulnerability | Treatment |
|--------|-----------------|------------|--------------|-------------------|--------------|-----------------|----------------|--|
| 01 | KAMPESKA #1 | 2005 | 29 | 29 | Permanent | Groundwater | Vulnerable | Treatment At Plant |
| 02 | KAMPESKA #2 | 2005 | 29 | 29 | Permanent | Groundwater | Vulnerable | Treatment At Plant |
| 03 | TREATMENT PLANT | | | | Permanent | Treatment Plant | Non-Vulnerable | Aeration Disinfection - Hypochlorites Filtration - Zeolite Fluoridation - H2SiF6 |

EPA ID#: 2277 System Name: Clark Rural Water-Kampeska

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

| Source | Type | Date | TDS | Conductance | pH | Alk-M | Alk-P | Na | K | Ca | Mg | Fe | Mn | Cl | SO4 | HCO3 | CO3 | Hardness | Langlier | NO3 | F |
|--------|---------|----------|-----|-------------|------|-------|-------|----|-----|------|------|------|------|------|-----|------|-----|----------|----------|-----|------|
| 03 | Treated | 12/18/09 | 364 | 714 | 7.42 | 214 | 0 | 11 | 3.5 | 74.2 | 27.5 | 0.03 | 0.02 | 84.0 | 10 | 261 | 0 | 298 | +0.10 | 3.4 | 1.08 |