

**EPA ID#: 2308 System Name: Klein School**

Sampler- Mr Tim Cournoyer Work Phone-(605)856-3509  
Title- Todd County Schools  
Address- PO Box 87  
Mission SD 57555

Location- City: Mission County: Todd  
Service Area- School  
PWS Owner Type- Private Ownership  
Water Supply Type- Groundwater Supply

Population Served- 25 Service Connections- 1

Months that System is Open to Public-Season Opening Date- September 1st Season Closing Date- May 31st

**Sources for Klein School**

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
03	#1		100	6	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant

**EPA ID#: 2308 System Name: Klein School**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	09/29/10	272	382	7.95	155	0	40	10.5	29.4	4.1	0.04	0.05	3.0	10	189	0	90	+0.11	2.2	0.38
03	Raw	10/09/13	269	388	7.85	180	0	38	11.4	34.9	4.6	0.00	0.03	3.0	0	220	0	106	+0.15	2.7	0.35
Averages			271	385	7.90	168	0	39	11.0	32.2	4.4	0.02	0.04	3.0	5	205	0	98		2.5	0.37