

EPA ID#: 2309 System Name: Southern Black Hills Water

Sampler- Mr Don Peterson Work Phone-(605)745-4669
Title- Manager
Address- 26858 US Hwy 385
Hot Springs SD 57747

Location- City: Hot Springs County: Custer, Fall River
Service Area- Other residential areas
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 350 Service Connections- 363

Sources for Southern Black Hills Water

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	STREETER WELL	2010	1000	10	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
02	TREATMENT PLANT				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites

EPA ID#: 2309 System Name: Southern Black Hills Water

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Raw	05/23/17	196	354	7.95	168	0	12	2.4	39.0	14.4	0.00	0.00	4.8	11	205	0	157	+0.26	0.5	0.37

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Treated	03/26/14	179	355	7.94	166	0	12	2.5	41.3	14.8	0.00	0.00	5.9	0	203	0	164	+0.27	0.5	0.34