

# EPA ID#: 2311 System Name: Canyon Springs Preserve

Sampler- Mr Ed Striebel Work Phone-(605)787-5653  
Title- Operator  
Address- 7005 Timberline Road  
Black Hawk SD 57718

Location- City: Rapid City County: Pennington  
Service Area- Trailer Court  
PWS Owner Type- Private Ownership  
Water Supply Type- Groundwater Supply

Population Served- 50 Service Connections- 21

## Sources for Canyon Springs Preserve HOA

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	2006	500	8	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
02	TREAT SITE				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites

**EPA ID#: 2311 System Name: Canyon Springs Preserve**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Treated	02/17/11	181	357	7.88	166	0	6	1.8	38.4	19.6	0.05	0.01	4.9	12	202	0	177	+0.18	0.5	0.20
02	Treated	05/13/14	112	248	8.30	101	0	6	1.6	25.3	10.7	0.00	0.00	8.0	10	124	0	107	+0.20	0.0	0.17
Averages			147	303	8.09	134	0	6	1.7	31.9	15.2	0.03	0.01	6.5	11	163	0	142		0.2	0.19