

**EPA ID#: 2336 System Name: Gilded Mountain Homeowners Association**

Sampler- Mr Steve Ryan Work Phone-  
Title- Operator  
Address- 1204 Washington Street  
Lead SD 57754

Location- City: Deadwood County: Lawrence  
Service Area- Other Transient Area  
PWS Owner Type- Private Ownership  
Water Supply Type- Groundwater Supply

Population Served- 45 Service Connections- 18

Months that System is Open to Public-Season Opening Date- January 1st Season Closing Date- December 31st

**Sources for Gilded Mountain Homeowners Association**

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	2008	1000	6	Emergency	Groundwater	Non-Vulnerable	Treatment At Plant
02	#2	2012	400	6	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
03	TREAT SITE - #2				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites

**EPA ID#: 2336 System Name: Gilded Mountain Homeowners Association**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
03	Treated	10/17/12	480	768	7.44	296	0	5	2.2	86.1	59.9	0.53	0.06	3.2	131	361	0	462	+0.34	0.5	0.50