

EPA ID#: 8063 System Name: United States Forest Service

Sampler- Ms Ty Gerbracht Work Phone-(605)574-4402
Title- Forest Rec Managemen
Address- PO Box 1168
Hill City SD 57745-1168

Location- City: Custer County: Pennington
Service Area- Recreation Area
PWS Owner Type- Federal Government
Water Supply Type- Groundwater Supply

Population Served- 79 Service Connections- 6

Months that System is Open to Public-Season Opening Date- May 20th Season Closing Date- September 15th

Sources for USFS-BHNF Horsethief Lake CG

| Source | Name | Year Built | Depth (feet) | Diameter (inches) | Availability | Type | Vulnerability | Treatment |
|--------|-----------------|------------|--------------|-------------------|--------------|-----------------|----------------|---|
| 01 | TREAT SITE - #1 | | | | Permanent | Treatment Plant | Non-Vulnerable | Disinfection - Hypochlorites Filtration - Cartridge Taste and Order Control |
| 03 | #1 | 1969 | 200 | 10 | Permanent | Groundwater | Non-Vulnerable | Treatment At Plant |

EPA ID#: 8063 System Name: United States Forest Service

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

| Source | Type | Date | TDS | Conductance | pH | Alk-M | Alk-P | Na | K | Ca | Mg | Fe | Mn | Cl | SO4 | HCO3 | CO3 | Hardness | Langlier | NO3 | F |
|--------|------|----------|-----|-------------|------|-------|-------|----|-----|-----|-----|------|------|-----|-----|------|-----|----------|----------|-----|------|
| 01 | Raw | 08/27/96 | 0 | 0 | 0.00 | 0 | 0 | 0 | 0.0 | 0.0 | 0.0 | 0.00 | 0.00 | 0.0 | 15 | 0 | 0 | 0 | 0.00 | 0.0 | 0.00 |

| Source | Type | Date | TDS | Conductance | pH | Alk-M | Alk-P | Na | K | Ca | Mg | Fe | Mn | Cl | SO4 | HCO3 | CO3 | Hardness | Langlier | NO3 | F |
|--------|---------|----------|-----|-------------|------|-------|-------|----|-----|------|-----|------|------|------|-----|------|-----|----------|----------|-----|------|
| 01 | Treated | 06/07/17 | 142 | 240 | 7.15 | 55 | 0 | 11 | 3.5 | 22.7 | 6.1 | 0.10 | 0.00 | 25.3 | 17 | 68 | 0 | 82 | -1.25 | 0.0 | 0.21 |