

You can contact us by calling or
write us at
300 W Bennett Ave
Forestburg SD 57314

Forestburg Well Company

2015 Drinking Water Report

It's your tap water!



EPA ID: 0129



Water Quality

Last year, the Forestburg Well Company monitored your drinking water for possible contaminants. This brochure is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies.

Water Source

We serve more than 54 customers an average of 4,050 gallons of water per day. Our water is groundwater that we produce from local wells. The state has performed an assessment of our source water and they have determined that the relative susceptibility rating for the Forestburg Well Company public water supply system is low.

For more information about your water and information on opportunities to participate in public meetings, call and ask for Jim Baysinger.

Additional Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants can be obtained by calling the Environment Protection Agency's Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Forestburg Well Company public water supply system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Detected Contaminants

The attached table lists all the drinking water contaminants that we detected during the 2015 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2015. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Violations

Your system had violations in 2015 and this report is being used as a public notice. Although these incidences were not an emergency, as customers, you have the right to know what happened and what we did to correct the situation. An alternative water supply was never needed and there is nothing you need to do at this time.

Information concerning these violations can be found on the attached Table of Violations. For additional information concerning any violation, please contact us. Please share this information with all the people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and business). You can do this by posting this notice in a public place or distributing copies by hand or by mail.

2015 Table of Detected Contaminants For Forestburg Well Company (EPA ID 0129)

Terms and abbreviations used in this table:

- * **Maximum Contaminant Level Goal(MCLG):** the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- * **Maximum Contaminant Level(MCL):** the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- * **Action Level(AL):** the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.
- * **Treatment Technique(TT):** A required process intended to reduce the level of a contaminant in drinking water. For turbidity, 95% of samples must be less than 0.3 NTU

Units:

- *MFL: million fibers per liter
- *mrem/year: millirems per year(a measure of radiation absorbed by the body)
- *NTU: Nephelometric Turbidity Units
- *pCi/l: picocuries per liter(a measure of radioactivity)
- *ppm: parts per million, or milligrams per liter(mg/l)
- *ppb: parts per billion, or micrograms per liter(ug/l)
- *ppt: parts per trillion, or nanograms per liter
- *ppq: parts per quadrillion, or picograms per liter
- *pspm: positive samples per month

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.0	0	09/23/14	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	0	0	09/23/14	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Substance	Highest Level Detected	Range	Date Tested	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Units	Major Source of Contaminant
Alpha emitters	1	ND - 1	12/26/11	15	0	pCi/l	Erosion of natural deposits.
Antimony	0.5		12/26/11	6	6	ppb	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.
Arsenic	2		12/26/11	10	NA	ppb	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium	0.013		12/26/11	2	2	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Chromium	4.3		12/26/11	100	100	ppb	Discharge from steel and pulp mills; erosion of natural deposits.
Fluoride	1.0		12/26/11	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Selenium	3.0		12/26/11	50	50	ppb	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.

Please direct questions regarding this information to Mr Jim Baysinger with the Forestburg Well Company public water system.

2015 Information on Violations For Forestburg Well Company (EPA ID 0129)

(This Drinking Water Report can be used as a Tier III Public Notice if distributed to each customer within 12 months of when the system was notified of the violation.)

Violation Type	Parameter	Date System Notified	Duration In Months	Health Effects Language	Action Taken By Your System
Failure to Take Source Samples	E. coli	01/05/15		We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Since we did not monitor for these contaminants we cannot be sure of the quality of the drinking water.	Back in compliance as of January 07, 2015.
Lack of Certified Operator	DBP Stage I	03/19/15			Back in compliance as of April 09, 2015.
DBP Failure To Monitor	DBP Failure To Monitor Chlorine	07/15/15		We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Since we did not monitor for these contaminants we cannot be sure of the quality of the drinking water.	Corrective action taken by your system: <input checked="" type="checkbox"/> We have since completed the required sampling and/or reporting. <input type="checkbox"/> We have taken additional measures within the water system administration to be sure that samples are taken properly in the future. <input type="checkbox"/> The proper number of samples was taken in the following month and we are now back in compliance with the sampling regulations. <input type="checkbox"/> Other(specify)_____
Failure to Monitor	Nitrate	01/04/16		We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Since we did not monitor for these contaminants we cannot be sure of the quality of the drinking water.	Corrective action taken by your system: <input type="checkbox"/> We have since completed the required sampling and/or reporting. <input type="checkbox"/> We have taken additional measures within the water system administration to be sure that samples are taken properly in the future. <input type="checkbox"/> The proper number of samples was taken in the following month and we are now back in compliance with the sampling regulations. <input type="checkbox"/> Other(specify)_____

For additional information concerning any violation please contact Mr Jim Baysinger with the Forestburg Well Company public water system.