

# The Standardized Monitoring Framework: A Quick Reference Guide

## Overview of the Framework

Title*	The Standardized Monitoring Framework (SMF), promulgated in the Phase II Rule on January 30, 1991 (56 FR 3526).
Purpose	To standardize, simplify, and consolidate monitoring requirements across contaminant groups. The SMF increases public health protection by simplifying monitoring plans and synchronizing monitoring schedules leading to increased compliance with monitoring requirements.
General Description	The SMF reduces the variability within monitoring requirements for chemical and radiological contaminants across system sizes and types.

\*This document provides a summary of federal drinking water requirements; to ensure full compliance, please consult the federal regulations at 40 CFR 141 and any approved state requirements.

## Additional Requirements

The SMF outlined on these pages summarizes existing systems' ongoing federal monitoring requirements only. Primacy agencies have the flexibility to issue waivers, with EPA approval, which take into account regional and state specific characteristics and concerns. To determine exact monitoring requirements, the SMF must be used in conjunction with any EPA approved waiver and additional requirements as determined by the primacy agency.

New water systems may have different and additional requirements as determined by the primacy agency.

## SMF Benefits

Implementation of the SMF results in . . .

- ▶ Increased public health protection through monitoring consistency.
- ▶ A reduction in the complexity of water quality monitoring from a technical and managerial perspective for both primacy agencies and water systems.
- ▶ Equalizing of resource expenditures for monitoring and vulnerability assessments.
- ▶ Increased water system compliance with monitoring requirements.

## Regulated Contaminants

<b>Inorganic Contaminants (IOCs)</b>	Fifteen (15) (Nitrate, Nitrite, total Nitrate/ Nitrite, and Asbestos are exceptions to SMF)
<b>Synthetic Organic Contaminants (SOCs) &amp; Volatile Organic Contaminants (VOCs)</b>	Fifty-One (51)
<b>Radionuclides</b>	Four (4)

## Utilities Covered

<b>All PWSs</b>	<b>Nitrate Nitrite</b>
<b>CWSs</b>	<b>IOCs SOCs VOCs Radionuclides</b>
<b>NTNCWSs</b>	<b>IOCs SOCs VOCs</b>

For additional information:

Call the Safe Drinking Water Hotline at 1-800-426-4791; visit the EPA web site at <http://water.epa.gov/drink> or contact your primacy agency's drinking water representatives.

See 40 CFR 141.23 regarding IOCs; 40 CFR 141.24 regarding VOCs and SOCs; and 40 CFR 141.26 regarding Radionuclides.



# STANDARDIZED MONITORING FRAMEWORK

	Second Cycle												Third Cycle								
	1st Period				2nd Period				3rd Period				1st Period			2nd Period			3rd Period		
	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019			
Nitrate	CWSs & NTNCWSs																				
	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****			
	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*			
Nitrite	TNCWSs																				
	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*			
	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****			
Radio-nuclides	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19			
	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****			
	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*			
Asbestos	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19			
	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****	****			
	Waiver	X		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X			
	No Waiver, Reliably and Consistently ≤ MCL, or vulnerable to asbestos contamination <sup>10</sup>																				
	> MCL																				

<b>Legend</b>
* = 1 sample at each entry point to distribution system (EPTDS).
** = 2 quarterly samples at each EPTDS. Samples must be taken during 1 calendar year during each 3-year compliance period.
*** = 4 quarterly samples at each EPTDS within time frame designated by the primary agency.
X = No sampling required unless required by the primary agency.
# = Systems must monitor at a frequency specified by the primary agency.
! = When allowed by the primary agency, data collected between June 2000 and December 6, 2003 may be grandfathered to satisfy the initial monitoring requirements due in 2004 for gross alpha, radium 226/228, and uranium.

<sup>1</sup>Until January 22, 2006 the maximum contaminant level (MCL) for arsenic is 50 µg/L; on January 23, 2006 the MCL for arsenic becomes 10 µg/L.

<sup>2</sup>Based on 3 rounds of monitoring at each EPTDS with all analytical results below the MCL. Waivers are not permitted under the current arsenic requirements, however systems are eligible for arsenic waivers after January 23, 2006.

<sup>3</sup>A system with a sampling point result above the MCL must collect quarterly samples, at that sampling point, until the system is determined by the primary agency to be reliably and consistently below the MCL.

<sup>4</sup>Samples must be taken during the quarter which previously resulted in the highest analytical result. Systems can apply for a waiver after 3 consecutive annual sampling results are below the detection limit.

<sup>5</sup>Groundwater systems must update their vulnerability assessments during the time the waiver is effective. Primary agencies must re-confirm that the system is non-vulnerable within 3 years of the initial determination or the system must return to annual sampling.

<sup>6</sup>If all monitoring results during initial quarterly monitoring are less than the detection limit, the system can take annual samples. If after a minimum of 3 years of annual sampling with all analytical results less than the detection limit, the primary agency can allow a system to take 1 sample during each compliance period. Systems are also eligible for a waiver.

<sup>7</sup>Primary agencies must determine that a surface water system is non-vulnerable based on a vulnerability assessment during each compliance period or the system must return to annual sampling.

<sup>8</sup>If all monitoring results during initial quarterly monitoring are less than the detection limit, the system can take annual samples. Systems are also eligible for a waiver.

<sup>9</sup>Samples must be taken during the quarter which previously resulted in the highest analytical result.

<sup>10</sup>Systems are required to monitor for asbestos during the first 3-year compliance period of each 9-year compliance cycle. A system vulnerable to asbestos contamination due solely to corrosion of asbestos-cement pipe must take 1 sample at a tap served by that pipe. A system vulnerable to asbestos contamination at the source must sample at each EPTDS.