

Town of Corona Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2015 Certificate of Achievement Award.

Population Served:	109	System Population:	109
Certified Operator:	Mr Don Settje PO Box 96 Corona, SD 57227-0096	Work Phone:	(605)467-0494
		Home Phone:	(605)432-6216
		Cell Phone:	
		Fax:	
		Email:	water.citymilbank@sstel.net
Financial Contact:	Ms Robin Schultz PO Box 96 Corona, SD 57227-0096	Work Phone:	(605)432-9385
		Home Phone:	(605)432-9385
		Cell Phone:	
		Fax:	
		Email:	
Other Contacts:	President JoAnn Settje PO Box 96 Corona, SD 57227-0096	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	March 20, 2014		
Type of System:	Community	Area Served:	Roberts County
Number of Service Connections:	55	Contamination Risk:	low
Water Produced And Used By The Town of Corona Public Water System			
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Monitoring/Reporting - Entry Point

Town of Corona

EPA ID: 0009

SAMPLING

Entry point: Treat Site - Well #1

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Triennially	No	Nov-13		
	B. Arsenic	Triennially	No	Nov-13		
	C. Barium	Triennially	No	Nov-13		
	D. Beryllium	Triennially	No	Nov-13		
	E. Cadmium	Triennially	No	Nov-13		
	F. Chromium	Triennially	No	Nov-13		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Triennially	No	Nov-13		
	I. Mercury	Triennially	No	Nov-13		
	J. Nickel	Triennially	No	Nov-13		
	K. Selenium	Triennially	No	Nov-13		
	L. Thallium	Triennially	No	Nov-13		
2	Radiological Chemicals	Every six years	N/A			
3	VOC Chemicals		No	Nov-14		
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Nov-14	2017	
	B. Method 524	Triennially	No	Nov-14	2017	
	C. Method 525	Triennially	No	Nov-14	2017	
	D. Method 531.1	Triennially	No	Nov-14	2017	
	E. Method 547	Triennially	No	Nov-14	2017	
	F. Method 548	Triennially	No	Nov-14	2017	
	G. Method 549	Triennially	No	Nov-14	2017	
5	Nitrate	Annually	N/A	Sep-16		
6	Nitrite	Triennially	N/A	Sep-16		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 29, 2014</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2014</u>
E	Lead - 90% Level	<u>1.8</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.085</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.76</u> mg/l
D	Running Annual Average:	<u>0.72</u> mg/l
E	Date of last DBP test:	<u>September 17, 2014</u>
F	THM - Qtr Average:	<u>0.53</u> ug/l
G	Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Corona

EPA ID: 0009

Violations From **October 1, 2011** To **October 1, 2016**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected