

City of Eagle Butte Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Operator Certification

Population Served:	4,000	System Population:	4,000
Certified Operator:	Mr Jon Ganje PO Box 150 Eagle Butte, SD 57625-0150	Work Phone:	(605)964-8784
		Home Phone:	
		Cell Phone:	
		Fax:	(605)964-8785
		Email:	sjganje@cityofeaglebutte.com
Financial Contact:	Ms Sheila Ganje PO Box 150 Eagle Butte, SD 57625-0150	Work Phone:	(605)964-8784
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	sjganje@cityofeaglebutte.com
Other Contacts:	Mayor Verzella LaPlante PO Box 150 Eagle Butte, SD 57625-0150	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	June 14, 2017		
Type of System:	Community	Area Served:	Dewey County
Number of Service Connections:	1,000	Contamination Risk:	low
Water Purchased From:			Tri-County Rural Water System (0112)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>48</u>
B Samples required:	<u>Four Samples Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>48</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	<u></u>

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>September 11, 2017</u>
B Samples required:	<u>20</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2017</u>
E Lead - 90% Level	<u>3.6</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.04</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>48</u>
B Samples required:	<u>Four Samples Each Month.</u>
C Last Qtr Cl Residual:	<u>0.73</u> mg/l
D Running Annual Average:	<u>0.84</u> mg/l
E Date of last DBP test:	<u>August 7, 2017</u>
F THM - Qtr Average:	<u>16.2</u> ug/l
G Haa5 - Qtr Average:	<u>11.35</u> ug/l

Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Eagle Butte

EPA ID: 0010

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected