

City of Avon Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served:	590	System Population:	590
Certified Operator:	Mr Allen Kocmich PO Box 207 Avon, SD 57315-0207	Work Phone:	(605)286-3747
		Home Phone:	(605)286-3207
		Cell Phone:	
		Fax:	(605)286-3694
		Email:	cityavon@gwtc.net
Financial Contact:	Ms Twyla Simmons PO Box 207 Avon, SD 57315-0207	Work Phone:	(605)286-3694
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cityavon@gwtc.net
Other Contacts:	Mayor Keith Gill PO Box 207 Avon, SD 57315-0207	Work Phone:	
		Home Phone:	(605)286-3619
		Cell Phone:	
		Fax:	
		Email:	kevin_charlene@yahoo.com
Last Inspection:	May 19, 2016		
Type of System:	Community	Area Served:	Bon Homme County
Number of Service Connections:	350	Contamination Risk:	low
Water Purchased From:			Bon Homme-Yankton RWS (0865)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	<u></u>

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 19, 2017</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2017</u>
E	Lead - 90% Level	<u>5.4</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>2.33</u> mg/l
D	Running Annual Average:	<u>2</u> mg/l
E	Date of last DBP test:	<u>September 29, 2016</u>
F	THM - Qtr Average:	<u>45.3</u> ug/l
G	Haa5 - Qtr Average:	<u>26.6</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Avon

EPA ID: 0031

Violations From

January 1, 2013

To

January 1, 2018

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected