

City of Belle Fourche Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2015 Certificate of Achievement Award.

Population Served:	5,594	System Population:	5,594
Certified Operator:	Mr Dirk Hoffman 511 Sixth Ave Belle Fourche, SD 57717	Work Phone:	(605)892-2494
		Home Phone:	
		Cell Phone:	
		Fax:	(605)892-2784
		Email:	pubworks@bellefourche.org
Financial Contact:	Ms Sharon Mins 511 Sixth Ave Belle Fourche, SD 57717	Work Phone:	(605)892-2494
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	sharon@bellefourche.org
Other Contacts:	Mayor Gloria Landphere 511 Sixth Ave Belle Fourche, SD 57717	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	April 23, 2015		
Type of System:	Community	Area Served:	Butte County
Number of Service Connections:	2,343	Contamination Risk:	low
Water Produced And Used By The City of Belle Fourche Public Water System			
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			Midcontinent Laboratory

Monitoring/Reporting - Entry Point

City of Belle Fourche

EPA ID: 0037

SAMPLING

Entry point: Treat Site - Well #2

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Triennially	No	Sep-15		
	B. Arsenic	Triennially	No	Sep-15		
	C. Barium	Triennially	No	Sep-15		
	D. Beryllium	Triennially	No	Sep-15		
	E. Cadmium	Triennially	No	Sep-15		
	F. Chromium	Triennially	No	Sep-15		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride		No			This system fluoridates
	I. Mercury	Triennially	No	Sep-15		
	J. Nickel	Triennially	No	Sep-15		
	K. Selenium	Triennially	No	Sep-15		
	L. Thallium	Triennially	No	Sep-15		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals		No	Sep-14		
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Apr-14	2017	
	B. Method 524	Triennially	No	Apr-14	2017	
	C. Method 525	Triennially	No	Apr-14	2017	
	D. Method 531.1	Triennially	No	Apr-14	2017	
	E. Method 547	Triennially	No	Apr-14	2017	
	F. Method 548	Triennially	No	Apr-14	2017	
	G. Method 549	Triennially	No	Apr-14	2017	
5	Nitrate	Annually	N/A	Sep-16		
6	Nitrite	Triennially	N/A	Sep-15		

(These values are calculated from available data. Check correspondence for verification.)

Monitoring/Reporting - Entry Point

City of Belle Fourche

EPA ID: 0037

SAMPLING

Entry point: Treat Site - Well #1

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Triennially	No	Sep-15		
	B. Arsenic	Triennially	No	Sep-15		
	C. Barium	Triennially	No	Sep-15		
	D. Beryllium	Triennially	No	Sep-15		
	E. Cadmium	Triennially	No	Sep-15		
	F. Chromium	Triennially	No	Sep-15		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride		No			This system fluoridates
	I. Mercury	Triennially	No	Sep-15		
	J. Nickel	Triennially	No	Sep-15		
	K. Selenium	Triennially	No	Sep-15		
	L. Thallium	Triennially	No	Sep-15		
2	Radiological Chemicals	Every six years	N/A			
3	VOC Chemicals		No	Sep-14		
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Apr-14	2017	
	B. Method 524	Triennially	No	Apr-14	2017	
	C. Method 525	Triennially	No	Apr-14	2017	
	D. Method 531.1	Triennially	No	Apr-14	2017	
	E. Method 547	Triennially	No	Apr-14	2017	
	F. Method 548	Triennially	No	Apr-14	2017	
	G. Method 549	Triennially	No	Apr-14	2017	
5	Nitrate	Annually	N/A	Sep-16		
6	Nitrite	Triennially	N/A	Sep-15		

(These values are calculated from available data. Check correspondence for verification.)

Monitoring/Reporting - Entry Point

City of Belle Fourche

EPA ID: 0037

SAMPLING

Entry point: Treat Site - Gallery

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Triennially	No	Sep-15		
	B. Arsenic	Triennially	No	Sep-15		
	C. Barium	Triennially	No	Sep-15		
	D. Beryllium	Triennially	No	Sep-15		
	E. Cadmium	Triennially	No	Sep-15		
	F. Chromium	Triennially	No	Sep-15		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride		No			This system fluoridates
	I. Mercury	Triennially	No	Sep-15		
	J. Nickel	Triennially	No	Sep-15		
	K. Selenium	Triennially	No	Sep-15		
	L. Thallium	Triennially	No	Sep-15		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals		No	Sep-14		
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Apr-14	2017	
	B. Method 524	Triennially	No	Apr-14	2017	
	C. Method 525	Triennially	No	Apr-14	2017	
	D. Method 531.1	Triennially	No	Apr-14	2017	
	E. Method 547	Triennially	No	Apr-14	2017	
	F. Method 548	Triennially	No	Apr-14	2017	
	G. Method 549	Triennially	No	Apr-14	2017	
5	Nitrate	Annually	N/A	Sep-16		
6	Nitrite	Triennially	N/A	Sep-15		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A Samples submitted:	<u>66</u>
B Samples required:	<u>Six Samples Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>66</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>September 20, 2014</u>
B Samples required:	<u>20</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2014</u>
E Lead - 90% Level	<u>3</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.17</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A Samples submitted:	<u>66</u>
B Samples required:	<u>Six Samples Each Month.</u>
C Last Qtr Cl Residual:	<u>0.42</u> mg/l
D Running Annual Average:	<u>0.35</u> mg/l
E Date of last DBP test:	<u>September 24, 2015</u>
F THM - Qtr Average:	<u>6.09</u> ug/l
G Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Belle Fourche

EPA ID: 0037

Violations From

October 1, 2011

To

October 1, 2016

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected