

Pine Hills Park Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



This system is not a candidate for an award:

Violation

Population Served:	300	System Population:	300
Certified Operator:	Mr Craig Price 6892 Polk Street Black Hawk, SD 57718	Work Phone:	(605)787-6617
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Financial Contact:	Mr Craig Price 6892 Polk Street Black Hawk, SD 57718	Work Phone:	(605)787-6617
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Other Contacts:	Ms Dixie Berzel 20251 Superior Place Whitewood, SD 57793	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	November 19, 2014		
Type of System:	Community	Area Served:	Meade County
Number of Service Connections:	119	Contamination Risk:	moderate
Water Purchased From:			Black Hawk Water User District (0043)
PWS Owner Type:	Private Ownership	Service Area:	TC/Mobile Home Park
Contract Laboratory:			Midcontinent Laboratory

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>13</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>1</u>
F	Repeat samples:	<u>3</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 25, 2014</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2014</u>
E	Lead - 90% Level	<u>1</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>13</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>2.83</u> mg/l
D	Running Annual Average:	<u>2.77</u> mg/l
E	Date of last DBP test:	<u>September 25, 2014</u>
F	THM - Qtr Average:	<u>0</u> ug/l
G	Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Pine Hills Park

EPA ID: 0041

Violations From October 1, 2011 To October 1, 2016

Violation Type	Parameter	Date	Status
FTM-Routine Samples	RTCR	08/01/2016	Public Notice Requested
Failure to Develop Sample Site Plan	RTCR	04/01/2016	Reminder Notice
Lack of Certified Operator	Certified Operator	02/01/2016	Reminder Notice
	DBP		Compliance Achieved
DBP Failure To Monitor	Chlorine	10/01/2015	Public Notice Requested
Lack of Certified Operator	Certified Operator	02/01/2015	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected